

2020 Annual Water Quality Report

(Testing Performed January through December 2019)

BLOUNTSVILLE UTILITIES DEPARTMENT

P.O. Box 157
69145 Main Street
Blountsville, AL 35031
Phone 205-429-2495
Fax 205-429-4744

We are pleased to present to you this year's Annual Water Quality Report, which is designed to inform you about the quality water we deliver to you every day. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water.

Water Sources	2 groundwater wells producing from Tuscumbia Limestone, Fort Payne Chert, & Maury Formations	
Water Treatment	Chlorine for disinfection	
Storage Capacity	3 tanks with a capacity of 840,000 gallons	
Distribution System	Approximately 55 miles of piping: 5 miles of cast/ductile iron & 50 miles of PVC	
Other Connections	Sell water to Blount County Water Authority and to Hanceville Water Works	
Number of Customers	Approximately 1475	
Board Members	Bobby Griffin, Chairman	Tommy Chambers, Member
	James M. Black, Vice Chairman	Don Griffin, Member
	Robert Murphy, Member	
Utilities Department Staff	David McAlpin, Manager/Superintendent	Gala Singleton, Secretary/Treasurer
	Lynn Goble, Senior Field Technician	Sonjia Thomas, Water Clerk
	Jeff Floyd, Utility Technician	Danett Dorning, Customer Service Representative

Source Water Assessment

In compliance with the Alabama Department of Environmental Management (ADEM), **Blountsville Utilities** has developed a Source Water Assessment plan that will assist in protecting our water sources. This plan provides additional information such as potential sources of contamination. It includes a susceptibility analysis, which classifies potential contaminants as high, moderate, or non-susceptible (low) to contaminating the water source. All of the potential contaminants sited in our study area were ranked as low. The assessment has been performed, public notification has been completed, and the plan has been approved by ADEM. A copy of the report is available in our office for review, or you may purchase a copy upon request for a nominal reproduction fee. Please help us make this effort worthwhile by protecting our source water. Carefully follow instructions on pesticides and herbicides you use for your lawn and garden, and properly dispose of household chemicals, paints and waste oil.

Monitoring Schedule

Blountsville Utilities routinely monitors for constituents in your drinking water according to Federal and State laws. This report contains results from the most recent monitoring which was performed in accordance with the regulatory schedule.

Constituents Monitored	Date Monitored
Inorganic Contaminants	2019
Lead/Copper	2017
Microbiological Contaminants	current
Nitrates	2019
Radioactive Contaminants	2019
Synthetic Organic Contaminants (including herbicides and pesticides)	2018
Volatile Organic Contaminants	2017
Disinfection By-products	2019

General Information

All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. MCL's, defined in a List of Definitions in this report, are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, storm water run-off, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- *Radioactive contaminants*, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water.

Based on a study conducted by ADEM with the approval of the EPA a statewide waiver for the monitoring of asbestos and dioxin was issued. Thus, monitoring for these contaminants was not required.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People at risk should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Information about Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Your water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking.

Use *only* water from the cold-water tap for drinking, cooking, and especially for making baby formula. Hot water is likely to contain higher levels of lead. The two actions recommended above are very important to the health of your family. They will probably be effective in reducing lead levels because most of the lead in household water usually comes from the plumbing in your house, not from the local water supply. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water hotline or at www.epa.gov/safewater.

Questions?

If you have any questions about this report or concerning your water utility, please contact **David McAlpin, Manager**, at 205-429-2495. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on **the first Tuesday of every month at 6:00 p.m. in the utilities board conference room at 69145 Main Street.**

More information about contaminants to drinking water and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (1-800-426-4791).

We have learned through our monitoring and testing that some constituents have been detected. We are pleased to report that our drinking water meets federal and state requirements.

TABLE OF DETECTED DRINKING WATER CONTAMINANTS						
Contaminants	Violation Y/N	Level Detected	Unit Msmt	MCLG	MCL	Likely Source of Contamination
Copper	NO	0.144 * 0>AL	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Nitrate [as Nitrogen]	NO	1.46-1.61	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
TTHM [Total trihalomethanes]	NO	Annual ND-1.10	ppb	0	80	By-product of drinking water chlorination
HAA5 [Haloacetic Acids]	NO	Annual ND-1.10	ppb	0	60	By-product of drinking water chlorination
Unregulated Contaminants						
Chloroform	NO	ND-0.86	ppb	70	none	Naturally occurring in the environment or as a result of industrial discharge or runoff
Bromodichloromethane	NO	ND-0.64	ppb	0	none	Naturally occurring in the environment or as a result of industrial discharge or runoff
Chlorodibromomethane	NO	ND-0.53	ppb	60	none	Naturally occurring in the environment or as a result of industrial discharge or runoff
Secondary Contaminants						
Chloride	NO	3.73-3.97	ppm	n/a	250	Naturally occurring in the environment or from runoff
Hardness	NO	124-144	ppm	n/a		Naturally occurring in the environment or as a result of treatment with water additives
pH	NO	8.14-8.18	S.U.	n/a	n/a	Naturally occurring in the environment or as a result of treatment with water additives
Sodium	NO	1.15-1.33	ppm	n/a	n/a	Naturally occurring in the environment
Sulfate	NO	4.85-5.05	ppm	n/a	250	Naturally occurring in the environment or from runoff
Total Dissolved Solids	NO	144-204	ppm	n/a	500	Naturally occurring in the environment or from runoff

* Figure shown is 90th percentile and # of sites above action level (1.3 ppm) = 0

DEFINITIONS

Action Level- the concentration of a contaminant that, if exceeded, triggers treatment or other requirements which a water system must follow.

Coliform Absent (ca)- Laboratory analysis indicates that the contaminant is not present.

Disinfection byproducts (DBPs)- are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water. Different disinfectants produce different types or amounts of disinfection byproducts. Disinfection byproducts for which regulations have been established include trihalomethanes (TTHM), haloacetic acids (HAA5), bromate, and chlorite.

Initial Distribution System Evaluation (IDSE)-a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs).

Locational Running Annual Average (LRAA)-yearly average of all the DPB results at each specific sampling site in the distribution system. The highest distribution site LRAA is reported in the Table of Detected Contaminants.

Maximum Contaminant Level-(mandatory language) The Maximum Allowed (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal-(mandatory language) The Goal (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)-the highest level of a disinfectant allowed in drinking water

Millirems per year (mrem/yr)-measure of radiation absorbed by the body.

Nephelometric Turbidity Unit (NTU)-a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND)- laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Not Reported (NR)-laboratory analysis, usually Secondary Contaminants, not reported by water system. EPA recommends secondary standards to water systems but does not require systems to comply.

Parts per billion (ppb) or Micrograms per liter (µg/l)-one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l)-one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)-one part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)-one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/L)-picocuries per liter is a measure of the radioactivity in water.

RAA-Running annual average

Standard Units (S.U.)-pH of water measures the water's balances of acids and bases and is affected by temperature and carbon dioxide gas. Water with less than 6.5 could be acidic, soft, and corrosive. A pH greater than 8.5 could indicate that the water is hard.

Treatment Technique (TT)- a required process intended to reduce the level of a contaminant in drinking water.

Variances & Exemptions (V&E)-State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

At the end of this report is a *Table of Primary Drinking Water Contaminants*. These contaminants were *not* detected in your water unless they appear in the *Table of Detected Contaminants*.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS					
Contaminant	MCL	Unit of Msmt	Contaminant	MCL	Unit of Msmt
Bacteriological Contaminants			o-Dichlorobenzene	600	ppb
Total Coliform Bacteria	<5%	present or absent	p-Dichlorobenzene	75	ppb
Fecal Coliform and E. coli	0	present or absent	1,2-Dichloroethane	5	ppb
Turbidity	TT	NTU	Nitrite	1	ppm
Radiological Contaminants			Total Nitrate and Nitrite	10	ppm
Beta/photon emitters	4	mrem/yr	Selenium	50	ppb
Alpha emitters	15	pCi/l	Thallium	2	ppb
Combined radium	5	pCi/l	Organic Contaminants		
Uranium	30	pCi/l	2,4-D	70	ppb
Inorganic Chemicals			2,4,5-TP (Silvex)	50	ppb
Antimony	6	ppb	Acrylamide	TT	
Arsenic	10	ppb	Alachlor	2	ppb
Asbestos	7	MFL	Benzo(a)pyrene [PAHs]	200	ppt
Barium	2	ppm	Carbofuran	40	ppb
Beryllium	4	ppb	Chlordane	2	ppb
Cadmium	5	ppb	Dalapon	200	ppb
Chromium	100	ppb	Di (2-ethylhexyl)adipate	400	ppb
Copper	AL=1.3	ppm	Di (2-ethylhexyl)phthalate	6	ppb
Cyanide	200	ppb	Dinoseb	7	ppb
Fluoride	4	ppm	Diquat	20	ppb
Lead	AL=15.	ppb	Dioxin [2,3,7,8-TCDD]	30	Picograms/l
Mercury	2	ppb	Chloramines	4	ppm
Nitrate	10	ppm	Chlorite	1	ppm
Endothall	100	ppb	HAA5 [Total haloacetic	60	ppb
Endrin	2	ppb	1,1-Dichloroethylene	7	ppb
Epichlorohydrin	TT		cis-1,2-Dichloroethylene	70	ppb
Glyphosate	700	ppb	trans-1,2-Dichloroethylene	100	ppb
Heptachlor	400	Nanograms/l	Dichloromethane	5	ppb
Heptachlor epoxide	200	Nanograms/l	1,2-Dichloropropane	5	ppb
Hexachlorobenzene	1	ppb	Ethylbenzene	700	ppb
Hexachlorocyclopentadiene	50	ppb	Ethylene dibromide	50	ppt
Lindane	200	Nanograms/l	Styrene	100	ppb
Methoxychlor	40	ppb	Tetrachloroethylene	5	ppb
Oxamyl [Vydate]	200	ppb	1,1,1-Trichloroethane	200	ppb
Oxamyl [Vydate]	200	PCBs	1,1,2-Trichloroethane	5	ppb
Pentachlorophenol	1	ppb	Trichloroethylene	5	ppb
Picloram	500	ppb	TTHM [Total	80	ppb
Simazine	4	ppb	Toluene	1	ppm
Toxaphene	3	ppb	Vinyl Chloride	2	ppb
Benzene	5	ppb	Xylenes	10	ppm
Carbon tetrachloride	5	ppb	Chlorine	4	ppm
Chlorobenzene	100	ppb	Chlorine Dioxide	800	ppb
Dibromochloropropane	200	ppt	Bromate	10	ppb
UNREGULATED CONTAMINANTS					
1,1 – Dichloropropene	Aldicarb	Chloroform	Metolachlor		
1,1,1,2-Tetrachloroethane	Aldicarb Sulfone	Chloromethane	Metribuzin		
1,1,2,2-Tetrachloroethane	Aldicarb Sulfoxide	Dibromochloromethane	N - Butylbenzene		
1,1-Dichloroethane	Aldrin	Dibromomethane	Naphthalene		
1,2,3 - Trichlorobenzene	Bromobenzene	Dicamba	N-Propylbenzene		
1,2,3 - Trichloropropane	Bromochloromethane	Dichlorodifluoromethane	O-Chlorotoluene		
1,2,4 - Trimethylbenzene	Bromodichloromethane	Dieldrin	P-Chlorotoluene		
1,3 – Dichloropropane	Bromoform	Hexachlorobutadiene	P-Isopropyltoluene		
1,3 – Dichloropropene	Bromomethane	Isopropylbenzene	Propachlor		
1,3,5 - Trimethylbenzene	Butachlor	M-Dichlorobenzene	Sec - Butylbenzene		
2,2 – Dichloropropane	Carbaryl	Methomyl	Tert - Butylbenzene		
3-Hydroxycarbofuran	Chloroethane	MTBE	Trichlorofluoromethane		